



It is the responsibility of the architect/owner to ensure that the hood clearance from limited-combustible and combustible materials is in compliance with local code requirements

Heat Hood (Type II)

- Hoods are built in accordance with NFPA 96, NSF Specifications and Conforms to UL 710 standard
- Hoods are constructed of 18 gauge 430 Stainless Steel
- All joints are welded liquid tight, without seams
- Wire Mesh Filter
- Factory does not cut holes in hood
 Hoods 10' and larger receive 6 hanger brackets total
- All Stainless Steel

